

2016 NEWPORT NEWS DISTISTRIBUTION SYSTEM Pb/Cu Monitoring

SAMPLE ID	LEAD, ug/L	COPPER, ug/L
1	<1.0	15.8
3	<1.0	41.0
4	<1.0	13.2
6	<1.0	53.3
7	<1.0	76.8
8	<1.0	27.0
9	<1.0	38.6
10	2.24	28.8
11	<1.0	30.3
12	<1.0	57.5
13	<1.0	37.5
14	<1.0	16.2
15	<1.0	44.3
16	<1.0	25.0
17	<1.0	71.4
18	<1.0	11.7
19	<1.0	52.0
20	<1.0	46.8
21	<1.0	32.1
22	<1.0	22.4
24	<1.0	11.1
25	<1.0	19.0
26	<1.0	23.1
27	<1.0	25.3
29	<1.0	33.8
30	<1.0	34.9
32	<1.0	58.5
33	<1.0	88.4
34	<1.0	32.4
36	<1.0	59.4
37	<1.0	33.0
38	<1.0	63.0
39	<1.0	30.0
40	<1.0	39.2
41	<1.0	15.4
43	<1.0	9.26
45	<1.0	45.4
46	<1.0	39.9
47	<1.0	36.2
49	3.07	81.4
50	<1.0	75.2
51	<1.0	80.1
52	<1.0	37.9
53	<1.0	32.5
54	<1.0	27.7
55	<1.0	30.4
56	<1.0	59.6
57	<1.0	33.7
58	<1.0	37.7

**2016 NEWPORT NEWS DISTISTRIBUTION SYSTEM Pb/Cu Monitoring**

SAMPLE ID	LEAD, ug/L	COPPER, ug/L
59	<1.0	20.8
Min	<1.0	9.26
Max	3.07	88.4
Median	<1.0	34.9
<b>90th Percentile</b>	<b>&lt;1.0</b>	<b>71.4</b>
# Samples	50	50